

The following chart provides the minimum isolation distance requirements established in Ohio Administrative Code (OAC) 3701-28-07 for private water systems. Refer to <http://codes.ohio.gov/oac/3701-28-07v1>, for the complete isolation distance rule language in OAC 3701-28-07.

This chart is provided as a courtesy and is not required to be submitted with the application and site plan.

Isolation Distance Requirements as per OAC 3701-28-07

Potential Source of Contamination	Minimum
If the potential source of contamination is not listed below	50 ft
Dwelling or building foundation	10 ft
Deck or porch, not part of the building foundation for basement or crawl space	5 ft
Road right-of-way	10 ft
Normal Road surface (edge of) when no right-of-way is designated	25 ft - only if this isolation distance gives a greater separation distance than the road utility easement
Road utility easement, when no right-of-way is designated	10 ft - only if this isolation distance gives a greater separation distance than the normal road surface
Driveway or parking lot (edge of)	5 ft
Lot lines / Easements	10 ft
Watertight sewers and drains (more than five feet from outside the building foundation)	10 ft
Sewage treatment system (STS)	50 ft
Gray water recycling system (GWRS) components	50 ft
Leaching pits (not properly abandoned)	100 ft
Dry wells (not properly abandoned)	100 ft
Watertight vault privies	50 ft
Leaching privies	100 ft
Wastewater treatment plant	300 ft
Drainage wells	100 ft
Properly sealed wells	5 ft
Private water system well (constructed properly)	10 ft
Public water system well (constructed properly)	outside the sanitary isolation radius of the public water well – OAC 3745-9-04(B)(2)
Water wells or boreholes of unknown or unregulated unpermitted construction	50 ft
Vertical open loop geothermal system, sealed with grout materials	25 ft
Horizontal or vertical closed loop geothermal system, utilizing propylene glycol	25 ft
Horizontal or vertical closed loop direct exchange geothermal system with circulating refrigerant or a heat transfer antifreeze other than propylene glycol	50 ft
Horizontal or vertical geothermal system of unknown or undocumented construction	50 ft
Streams, lakes, ponds and other permanent bodies of water	25 ft
Storm water structure / special conduits / ditches with intermittent water flow	15 ft
Bulk salt storage piles	100 ft
Fuel operated motors used for well pumps without secondary containment	50 ft
Fuel oil, diesel, chemical, or gasoline storage tanks or other petroleum liquids (less than 1,100 gal)	50 ft
Fuel oil, diesel, chemical or gasoline storage tanks or other petroleum liquids (greater than 1,100 gallons without secondary containment)	300 ft
Natural gas or propane (LP/liquid propane) home heating tanks above or below ground	20 ft
Oil and gas wells or the oil and gas well pad	100 ft
Municipal solid waste, residential waste, industrial waste, and Class I, II, III solid waste composting facilities	1000 ft
Construction and demolition debris solid waste facility and Class IV solid waste composting facilities	500 ft
A regional storage facility or other bulk storage facility for biosolids (sludge)	300 ft
Grass pasture with large animals (with barrier around well component)	5 ft
Animal waste management facility located at major, large, or medium concentrated animal feeding facilities (AFF)	300 ft
Animal waste management facility located at an AFF <u>not</u> designated concentration as major, large, or medium	150 ft
Animal housing or holding pens with no grass cover, stables, manure piles, fabricated manure storage and animal waste or treatment buildings not located at an AFF	50 ft
Land application of septage waste, manure, or biosolids (sludge) stockpile, storage or staging area where the Ohio EPA has determined the aquifer has a high susceptibility to contamination	300 ft
Surface land application area for septage, biosolids (sludge), commercially land applied manure, or other similar materials previously approved by Ohio EPA or the board of health	200 ft
Subsurface incorporation application area using septage, biosolids (sludge), commercially produced manure, or other similar materials previously approved by the Ohio EPA or the board of health	100 ft
Storage or preparation area for commercial application of fertilizers or pesticides	150 ft